

Chester County
natural gas authority
The "Natural" Solution

POLICY ON USE OF CSST (CORRUGATED STAINLESS STEEL TUBING) ON 7" W.C. PRESSURE SYSTEMS WITHIN THE CCNGA SYSTEM

These guidelines have been implemented by Chester County Natural Gas Authority as a guide to allow use of CSST. The Authority may at anytime update, change, or delete any part of this policy.

This policy should not be confused with the Chester County Natural Gas Authority policy on the use of prefabricated metallic flexible connectors.

- 1. All CSST must be AGA approved and identified permanently as such.**
- 2. CSST use is limited to interior use only (no exposure to weather). All entry or exit through foundation or exterior walls will be black iron pipe.**
- 3. CSST must be sized for BTU Load in accordance with CSST sizing table.**
- 4. No connections should be inside walls or concealed areas.**
- 5. Use of CSST will still require proper strapping to prevent loose hanging pipe from the origin point to the termination point.**
- 6. Any section of CSST shall not be used to support any other section of piping connected to it; each section should be properly strapped or supported.**